



America

CERTIFICATE

No. U8V 09 06 22795 076

Holder of Certificate: **Leuze electronic GmbH + Co. KG**


Liebigstrasse 4
82256 Fürstfeldbruck
GERMANY

Production

22795, 63063

Facility(ies):

Certification Mark:



Product:

Electro-Sensitive Protective Equipment
(Laser Scanner)

Model(s):

Rotoscan RS4-2E, RS4-2M, RS4-4,
RS4-4E, RS4-4M, RS4-6E, RS4-6M

Parameters:

Input Voltage, DC:	24 V
Input Power:	28 W
Protection Class:	III
Laser Class:	Class I per CFR 1040 & RDER C1370
Temperature, Ambient:	55°C

Conditions of Acceptability:

- The devices are defined as Class III equipment in which protection against electric shock relies upon supply form SELV CIRCUITS and in which HAZARDOUS VOLTAGES are not generated as per IEC 60950-1 1st Edition.
- The supply source is not parts of this approval.

Tested

according to:

CAN/CSA-C22.2 No. 14:2005,
UL 508/R:2005-07
(Supplemented by
CAN/CSA-E61496-1:2004, CAN/CSA-E61496-2:2004,
UL 61496-1/R:2007-02, UL 61496-2/R:2007-02
IEC 61496-3:2001)

The product is intended and certified for Canada and USA. Additional requirements may apply in other countries.

The product was voluntarily tested according to the relevant safety requirements and mentioned properties. It can be marked with the certification mark shown above. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.:

231-809031A-000

Date, 2009-06-10

Page 1 of 1

